

Certificate of Conformity

Number: C211-0044/16 M1 **Project file:** C20162514

Product: Installation conduits

Type reference: RFSS 16 – 60 Ma, RFSS 16 – 60 Br

Trademark: PRIZMA - FLEKS

Applicant: PRIZMA - FLEKS d.o.o.
Bognarjeva pot 1, SI-1000 Ljubljana, Slovenia

Manufacturer: PRIZMA - FLEKS d.o.o.
Bognarjeva pot 1, SI-1000 Ljubljana, Slovenia

Place of manufacture: PRIZMA - FLEKS d.o.o.
Bognarjeva pot 1, SI-1000 Ljubljana, Slovenia

This certificate is granted subject to the SIQ's rules on product certification. SIQ certifies the conformity of the products with the requirements of the listed standards.

Ratings: See next page

Standard: EN 61386-22:2004 + A11:2010; EN 61386-1:2008

Test report: T211-0677/16 M1

Remarks: This certificate shall apply to the products identical to the tested sample and shall remain valid for the period of 3 years until 2019-10-05 or until the validity date of the listed standards, whichever occurs earlier.

This Certificate replaces previously issued Certificate No.: C211-0044/16 due to typing error.

Date: 2016-10-05

Authorized signature:

Bojan Pečavar



Only integral publication of this certificate is allowed. This certificate may only be reproduced in its entirety and without any changes. On request SIQ will give information about the validity of the certificate.

Certificate of Conformity

Number: C211-0044/16 M1

Ratings:

Type	Color	Resistance to compression	Resistance to impact	Lower temperature range	Upper temperature range
RFSS 16 – 60 Ma	Grey	125 N (Very Light)	Medium (2 kg/100 mm)	-15°C	+60°C
RFSS 16 – 60 Br	Grey	125 N (Very Light)	Medium (2 kg/100 mm)	-15°C	+60°C

Date: 2016-10-05

Authorized signature:

Bojan Pečavar

